

Table 1
Summary of Analytical Testing Results
Perfluorinated Compound Monitoring Program
Pease Air Force Base, New Hampshire

Sample ID	FIRESTATION3_12012015	USEPA Provisional Health Advisory
Collection Date	12-Dec-15	
Sample Results Units	µg/L	µg/L
6:2 Fluorotelomer sulfonate (6:2 FTS)	ND	-
8:2 Fluorotelomer sulfonate (8:2 FTS)	ND	-
N-Ethyl perfluorooctane sulfonamide (EtFOSA)	ND	-
N-Ethyl perfluorooctane sulfonamidoethanol (EtFOSE)	ND	-
N-Methyl Perfluorooctane Sulfonamide (MEFOSA)	ND	-
N-Methyl Perfluorooctane Sulfonamidoethanol (MEFOSE)	ND	-
Perfluorobutanesulfonic acid (PFBS)	0.0065 J	-
Perfluorobutanoic acid (PFBA)	0.013 J	-
Perfluorodecane sulfonate (PFDS)	ND	-
Perfluorodecanoic acid (PFDA)	ND	-
Perfluorododecanoic acid (PFDoA)	ND	-
Perfluoroheptane sulfonate (PFHpS)	ND	-
Perfluoroheptanoic acid (PFHpA)	ND	-
Perfluorohexanesulfonic acid (PFHxS)	0.019 J	-
Perfluorohexanoic acid (PFHxA)	0.007 J	-
Perfluorononanoic acid (PFNA)	ND	-
Perfluorooctane sulfonamide (PFOSA)	ND	-
Perfluorooctanesulfonic acid (PFOS)	0.013 J	0.2
Perfluorooctanoic acid (PFOA)	0.0055 J	0.4
Perfluoropentanoic acid (PFPeA)	0.0037 J	-
Perfluorotetradecanoic acid (PFTeDA)	ND	-
Perfluorotridecanoic acid (PFTrDA)	ND	-
Perfluoroundecanoic acid (PFUnA)	ND	-

Notes:

Grey text indicates the parameter was not detected.

USEPA - U.S. Environmental Protection Agency

E537 - EPA analytical method

µg/L - micrograms per liter

ND - not detected

"-" - No Provisional Health Advisory screening level established

"J" - Estimated